

TÜRK STANDARDLARI ENSTİTÜSÜ
ELEKTROMANYETİK UYUMLULUK BELGESİ EKİ
TURKISH STANDARDS INSTITUTION
ELECTROMAGNETIC COMPATIBILITY CERTIFICATE APPENDIX

BELGE NUMARASI
REFERENCE NUMBER OF LICENCE

14.0.30.4.34.00/EMC-094

ÜRÜN
PRODUCT

KESİNTİSİZ GÜÇ SİSTEMİ

BELGENİN İLK VERİLİŞ TARİHİ
DATE OF FIRST ISSUE OF LICENCE

24/12/2024

BELGENİN SON GEÇERLİLİK TARİHİ
LICENCE VALID UNTIL

24/12/2025

BELGE SAHİBİ KURULUŞUN ADI
NAME OF THE LICENCE HOLDER

İNFORM ELEKTRONİK SANAYİ VE TİCARET ANONİM ŞİRKETİ

BELGE SAHİBİ KURULUŞUN ADRESİ
ADDRESS OF THE LICENCE HOLDER

ESENŞEHİR MAH. HALE SK. NO:6 /1 /1 ÜMRANIYE

ÜRETİM YERİ ADI
NAME OF THE MANUFACTURING PLACE

İNFORM ELEKTRONİK SANAYİ VE TİCARET ANONİM ŞİRKETİ GEBZE ŞUBESİ

ÜRETİM YERİ ADRESİ
ADDRESS OF THE MANUFACTURING PLACE

PELİTLİ MAHALLESİ 4440 SOKAK ARÇELİK SİTESİ NO:12 GEBZE

TESCİLLİ TİCARİ MARKASI
REGISTERED TRADE MARK

inform

İLGİLİ TÜRK STANDARDI
RELATED TURKISH STANDARD

TS EN IEC 62040-2

REFERANS TEST RAPOR NO
TEST REPORT REF. NO

MODEL / TİP REF.
MODEL / TYPE REF.

BELGE KAPSAMI
SCOPE OF LICENCE

-PDSP 33010 MODEL, 3x400V, 10kVA, 8kW, Cosφ:0.8, 18Amax, 50/60Hz, Class I, IP20
-PDSP 33015 MODEL, 3x400V, 15kVA, 12kW, Cosφ:0.8, 26Amax, 50/60Hz, Class I, IP20
-PDSP 33020 MODEL, 3x400V, 20kVA, 16kW, Cosφ:0.8, 33Amax, 50/60Hz, Class I, IP20
-PDSP 33030 MODEL, 3x400V, 30kVA, 24kW, Cosφ:0.8, 49Amax, 50/60Hz, Class I, IP20
-PDSP 33040 MODEL, 3x400V, 40kVA, 32kW, Cosφ:0.8, 69Amax, 50/60Hz, Class I, IP20
-PDSP 33060 MODEL, 3x400V, 60kVA, 48kW, Cosφ:0.8, 101Amax, 50/60Hz, Class I, IP20
-PDSP 33080 MODEL, 3x400V, 80kVA, 64kW, Cosφ:0.8, 133Amax, 50/60Hz, Class I, IP20
-UPS FORTE 33010 MODEL, 3x400V, 10kVA, 10kW, Cosφ:1.0, 18Amax, 50/60Hz, Class I, IP20
-UPS FORTE 33015 MODEL, 3x400V, 15kVA, 15kW, Cosφ:1.0, 28Amax, 50/60Hz, Class I, IP20
-UPS FORTE 33020 MODEL, 3x400V, 20kVA, 20kW, Cosφ:1.0, 35Amax, 50/60Hz, Class I, IP20
-UPS FORTE 33030 MODEL, 3x400V, 30kVA, 30kW, Cosφ:1.0, 53Amax, 50/60Hz, Class I, IP20
-UPS FORTE 33040 MODEL, 3x400V, 40kVA, 40kW, Cosφ:1.0, 71Amax, 50/60Hz, Class I, IP20
-UPS FORTE 33060 MODEL, 3x400V, 60kVA, 60kW, Cosφ:1.0, 106Amax, 50/60Hz, Class I, IP20
-UPS FORTE 33080 MODEL, 3x400V, 80kVA, 80kW, Cosφ:1.0, 142Amax, 50/60Hz, Class I, IP20
-UPS FORTE 33100 MODEL, 3x400V, 100kVA, 100kW, Cosφ:1.0, 174Amax, 50/60Hz, Class I, IP20
-UPS FORTE 33120 MODEL, 3x400V, 120kVA, 120kW, Cosφ:1.0, 212Amax, 50/60Hz, Class I, IP20
-UPS FORTE 33160 MODEL, 3x400V, 160kVA, 160kW, Cosφ:1.0, 283Amax, 50/60Hz, Class I, IP20
-UPS FORTE 33200 MODEL, 3x400V, 200kVA, 200kW, Cosφ:1.0, 353Amax, 50/60Hz, Class I, IP20
-UPS FORTE 33250 MODEL, 3x400V, 250kVA, 250kW, Cosφ:1.0, 428Amax, 50/60Hz, Class I, IP20
-UPS FORTE COMPACT 33010 MODEL, 3x400V, 10kVA, 10kW, Cosφ:1.0, 18Amax, 50/60Hz, Class I, IP20 (K.G.:23.08.2022)
-UPS ETR EVO COMPACT 33010 MODEL, 3x400V, 10kVA, 10kW, Cosφ:1.0, 18Amax, 50/60Hz, Class I, IP20 (K.G.:23.08.2022)
-UPS FORTE COMPACT 33015 MODEL, 3x400V, 15kVA, 15kW, Cosφ:1.0, 28Amax, 50/60Hz, Class I, IP20 (K.G.:23.08.2022)
-UPS ETR EVO COMPACT 33015 MODEL, 3x400V, 15kVA, 15kW, Cosφ:1.0, 28Amax, 50/60Hz, Class I, IP20 (K.G.:23.08.2022)
-UPS FORTE COMPACT 33020 MODEL, 3x400V, 20kVA, 20kW, Cosφ:1.0, 35Amax, 50/60Hz, Class I, IP20 (K.G.:23.08.2022)
-UPS ETR EVO COMPACT 33020 MODEL, 3x400V, 20kVA, 20kW, Cosφ:1.0, 35Amax, 50/60Hz, Class I, IP20 (K.G.:23.08.2022)
-UPS ETR EVO 33010 MODEL, 3x400V, 10kVA, 10kW, Cosφ:1.0, 18Amax, 50/60Hz, Class I, IP20 (K.G.:23.08.2022)
-UPS ETR EVO 33015 MODEL, 3x400V, 15kVA, 15kW, Cosφ:1.0, 28Amax, 50/60Hz, Class I, IP20 (K.G.:23.08.2022)
-UPS ETR EVO 33020 MODEL, 3x400V, 20kVA, 20kW, Cosφ:1.0, 35Amax, 50/60Hz, Class I, IP20 (K.G.:23.08.2022)

24/12/2025

Belgelendirme Merkezi Başkanı Adına



TÜRK STANDARDLARI ENSTİTÜSÜ

ELEKTROMANYETİK UYUMLULUK BELGESİ EKİ

TURKISH STANDARDS INSTITUTION

ELECTROMAGNETIC COMPATIBILITY CERTIFICATE APPENDIX

- UPS ETR EVO 33030 MODEL, 3x400V, 30kVA, 30kW, Cosφ:1.0, 53Amax, 50/60Hz, Class I, IP20 (K.G.:23.08.2022)
- UPS KEOR T EVO 1020 33010 (H0, H1, H2) MODEL, 3x400V, 10kVA, 10kW, Cosφ:1.0, 18Amax, 50/60Hz, Class I, IP20 (K.G.:23.08.2022)
- UPS KEOR T EVO 1020 33015 (H0, H1, H2) MODEL, 3x400V, 15kVA, 15kW, Cosφ:1.0, 26Amax, 50/60Hz, Class I, IP20 (K.G.:23.08.2022)
- UPS KEOR T EVO 1020 33020 (H0, H1, H2) MODEL, 3x400V, 20kVA, 20kW, Cosφ:1.0, 35Amax, 50/60Hz, Class I, IP20 (K.G.:23.08.2022)
- UPS KEOR T EVO 1345 33010 (H P0, H P1, H P2) MODEL, 3x400V, 10kVA, 10kW, Cosφ:1.0, 18Amax, 50/60Hz, Class I, IP20 (K.G.:23.08.2022)
- UPS KEOR T EVO 1345 33015 (H P0, H P1, H P2) MODEL, 3x400V, 15kVA, 15kW, Cosφ:1.0, 26Amax, 50/60Hz, Class I, IP20 (K.G.:23.08.2022)
- UPS KEOR T EVO 1345 33020 (H P0, H P1, H P2) MODEL, 3x400V, 20kVA, 20kW, Cosφ:1.0, 35Amax, 50/60Hz, Class I, IP20 (K.G.:23.08.2022)
- UPS KEOR T EVO 1345 33030 (H P0, H P1) MODEL, 3x400V, 30kVA, 30kW, Cosφ:1.0, 54Amax, 50/60Hz, Class I, IP20 (K.G.:23.08.2022)
- UPS KEOR T EVO 1650 33010 (H P0, H P3) MODEL, 3x400V, 10kVA, 10kW, Cosφ:1.0, 18Amax, 50/60Hz, Class I, IP20 (K.G.:23.08.2022)
- UPS KEOR T EVO 1650 33015 (H P0, H P3) MODEL, 3x400V, 15kVA, 15kW, Cosφ:1.0, 26Amax, 50/60Hz, Class I, IP20 (K.G.:23.08.2022)
- UPS KEOR T EVO 1650 33020 (H P0, H P3) MODEL, 3x400V, 20kVA, 20kW, Cosφ:1.0, 35Amax, 50/60Hz, Class I, IP20 (K.G.:23.08.2022)
- UPS KEOR T EVO 1650 33030 (H P0, H P2, H P3) MODEL, 3x400V, 30kVA, 30kW, Cosφ:1.0, 54Amax, 50/60Hz, Class I, IP20 (K.G.:23.08.2022)
- UPS ETR EVO 33040 MODEL, 3x400V, 40kVA, 40kW, Cosφ:1.0, 71Amax, 50/60Hz, Class I, IP20 (K.G.:23.08.2022)
- UPS ETR EVO 33060 MODEL, 3x400V, 60kVA, 60kW, Cosφ:1.0, 106Amax, 50/60Hz, Class I, IP20 (K.G.:23.08.2022)
- UPS KEOR T EVO 1650 33040 (H P0, H P1, H P2, H P3) MODEL, 3x400V, 40kVA, 40kW, Cosφ:1.0, 72Amax, 50/60Hz, Class I, IP20 (K.G.:23.08.2022)
- UPS KEOR T EVO 1650 33060 (H P0, H P1, H P2) MODEL, 3x400V, 60kVA, 60kW, Cosφ:1.0, 108Amax, 50/60Hz, Class I, IP20 (K.G.:23.08.2022)
- UPS ETR EVO 33080 MODEL, 3x400V, 80kVA, 80kW, Cosφ:1.0, 142Amax, 50/60Hz, Class I, IP20 (K.G.:23.08.2022)
- UPS ETR EVO 33100 MODEL, 3x400V, 100kVA, 100kW, Cosφ:1.0, 174Amax, 50/60Hz, Class I, IP20 (K.G.:23.08.2022)
- UPS ETR EVO 33120 MODEL, 3x400V, 120kVA, 120kW, Cosφ:1.0, 212Amax, 50/60Hz, Class I, IP20 (K.G.:23.08.2022)
- UPS ETR EVO 33160 MODEL, 3x400V, 160kVA, 160kW, Cosφ:1.0, 283Amax, 50/60Hz, Class I, IP20 (K.G.:23.08.2022)
- UPS ETR EVO 33200 MODEL, 3x400V, 200kVA, 200kW, Cosφ:1.0, 353Amax, 50/60Hz, Class I, IP20 (K.G.:23.08.2022)
- UPS ETR EVO 33250 MODEL, 3x400V, 250kVA, 250kW, Cosφ:1.0, 428Amax, 50/60Hz, Class I, IP20 (K.G.:23.08.2022)
- UPS Solutio 33300 MODEL, 3x400V, 300kVA, 300kW, Cosφ:1.0, 507Amax, 50/60Hz, Class I, IP20 (K.G.:23.08.2022)
- UPS Solutio 33300 SPBYP MODEL, 3x400V, 300kVA, 300kW, Cosφ:1.0, 507Amax, 50/60Hz, Class I, IP20 (K.G.:23.08.2022)
- UPS FORTE 33300 MODEL, 3x400V, 300kVA, 300kW, Cosφ:1.0, 507Amax, 50/60Hz, Class I, IP20 (K.G.:23.08.2022)
- UPS FORTE 33300 SPBYP MODEL, 3x400V, 300kVA, 300kW, Cosφ:1.0, 507Amax, 50/60Hz, Class I, IP20 (K.G.:23.08.2022)
- UPS KEOR T EVO 33300 MODEL, 3x400V, 300kVA, 300kW, Cosφ:1.0, 507Amax, 50/60Hz, Class I, IP20 (K.G.:23.08.2022)
- UPS KEOR T EVO 33300 SPBYP MODEL, 3x400V, 300kVA, 300kW, Cosφ:1.0, 507Amax, 50/60Hz, Class I, IP20 (K.G.:23.08.2022)
- UPS ETR EVO 33300 MODEL, 3x400V, 300kVA, 300kW, Cosφ:1.0, 507Amax, 50/60Hz, Class I, IP20 (K.G.:23.08.2022)
- UPS ETR EVO 33300 SPBYP MODEL, 3x400V, 300kVA, 300kW, Cosφ:1.0, 507Amax, 50/60Hz, Class I, IP20 (K.G.:23.08.2022)
- UPS Solutio 33400 MODEL, 3x400V, 400kVA, 400kW, Cosφ:1.0, 676Amax, 50/60Hz, Class I, IP20 (K.G.:23.08.2022)
- UPS Solutio 33400 SPBYP MODEL, 3x400V, 400kVA, 400kW, Cosφ:1.0, 676Amax, 50/60Hz, Class I, IP20 (K.G.:23.08.2022)
- UPS FORTE 33400 MODEL, 3x400V, 400kVA, 400kW, Cosφ:1.0, 676Amax, 50/60Hz, Class I, IP20 (K.G.:23.08.2022)
- UPS FORTE 33400 SPBYP MODEL, 3x400V, 400kVA, 400kW, Cosφ:1.0, 676Amax, 50/60Hz, Class I, IP20 (K.G.:23.08.2022)
- UPS KEOR T EVO 33400 MODEL, 3x400V, 400kVA, 400kW, Cosφ:1.0, 676Amax, 50/60Hz, Class I, IP20 (K.G.:23.08.2022)
- UPS KEOR T EVO 33400 SPBYP MODEL, 3x400V, 400kVA, 400kW, Cosφ:1.0, 676Amax, 50/60Hz, Class I, IP20 (K.G.:23.08.2022)
- UPS ETR EVO 33400 MODEL, 3x400V, 400kVA, 400kW, Cosφ:1.0, 676Amax, 50/60Hz, Class I, IP20 (K.G.:23.08.2022)
- UPS ETR EVO 33400 SPBYP MODEL, 3x400V, 400kVA, 400kW, Cosφ:1.0, 676Amax, 50/60Hz, Class I, IP20 (K.G.:23.08.2022)
- UPS ESTIA TOWER 33010 10kVA / 9kW 400V (±15%) Cosφ:0,9 max. 15A Class 1 IP20 380 / 400 / 415V (±1%) 15A / 14A / 14A 6kA lcv:75A(1s) (K.G.:23.12.2024)
- UPS ESTIA TOWER 33015 15kVA / 13,5kW 400V (±15%) Cosφ:0,9 max. 23A Class 1 IP20 380 / 400 / 415V (±1%) 23A / 22A / 21A 6kA lcv:115A(1s) (K.G.:23.12.2024)
- UPS ESTIA TOWER 33020 20kVA / 18kW 400V (±15%) Cosφ:0,9 max. 30A Class 1 IP20 380 / 400 / 415V (±1%) 30A / 29A / 28A 6kA lcv:150A(1s) (K.G.:23.12.2024)
- UPS ESTIA EVO TOWER 33010 10kVA / 9kW 400V (±15%) Cosφ:0,9 max. 15A Class 1 IP20 3N 380 / 400 / 415V (±1%) 15A / 14A / 14A 6kA lcv:75A(1s) (K.G.:23.12.2024)
- UPS ESTIA EVO TOWER 33015 15kVA / 13,5kW 400V (±15%) Cosφ:0,9 max. 23A Class 1 IP20 380 / 400 / 415V (±1%) 23A / 22A / 21A 6kA lcv:115A(1s) (K.G.:23.12.2024)
- UPS ESTIA EVO TOWER 33020 20kVA / 18kW 400V (±15%) Cosφ:0,9 max. 30A Class 1 IP20 380 / 400 / 415V (±1%) 30A / 29A / 28A 6kA lcv:150A(1s) (K.G.:23.12.2024)
- UPS ESTIA TOWER 33030 30kVA / 27kW 400V (±15%) Cosφ:0,9 max. 53A Class 1 IP20 380 / 400 / 415V (±1%) 45A / 43A / 42A 6kA lcv:265A(1s) (K.G.:23.12.2024)
- UPS ESTIA TOWER 33040 40kVA / 36kW 400V (±15%) Cosφ:0,9 max. 71A Class 1 IP20 380 / 400 / 415V (±1%) 61A / 58A / 56A 10kA lcv:355A(1s) (K.G.:23.12.2024)
- UPS ESTIA TOWER 33060 60kVA / 54kW 400V (±15%) Cosφ:0,9 max. 107A Class 1 IP20 380 / 400 / 415V (±1%) 91A / 87A / 83A 10kA lcv:535A(1s) (K.G.:23.12.2024)
- UPS ESTIA TOWER 33030 30kVA / 27kW 400V (±15%) Cosφ:0,9 max. 53A Class 1 IP20 380 / 400 / 415V (±1%) 45A / 43A / 42A 6kA lcv:265A(1s) (K.G.:23.12.2024)
- UPS ESTIA EVO TOWER 33040 40kVA / 36kW 400V (±15%) Cosφ:0,9 max. 71A Class 1 IP20 380 / 400 / 415V (±1%) 61A / 58A / 56A 10kA lcv:355A(1s) (K.G.:23.12.2024)
- UPS ESTIA EVO TOWER 33060 60kVA / 54kW 400V (±15%) Cosφ:0,9 max. 107A Class 1 IP20 380 / 400 / 415V (±1%) 91A / 87A / 83A 10kA lcv:535A(1s) (K.G.:23.12.2024)
- UPS ESTIA HYBRID 33015 15kVA / 13,5kW 400V (±15%) Cosφ:0,8 max. 23A Class 1 IP20 380 / 400 / 415V (±1%) 23A / 22A / 21A 6kA lcv:115A(1s) (K.G.:23.12.2024)
- UPS ESTIA HYBRID 33015 15kVA / 13,5kW 400V (±15%) Cosφ:0,9 max. 23A Class 1 IP20 380 / 400 / 415V (±1%) 23A / 22A / 21A 6kA lcv:115A(1s) (K.G.:23.12.2024)
- UPS ESTIA EVO HYBRID 33015 15kVA / 13,5kW 400V (±15%) Cosφ:0,9 max. 23A Class 1 IP20 380 / 400 / 415V (±1%) 23A / 22A / 21A 6kA lcv:115A(1s) (K.G.:23.12.2024)
- UPS ESTIA HYBRID 33020 20kVA / 18kW 400V (±15%) Cosφ:0,8 max. 30A Class 1 IP20 380 / 400 / 415V (±1%) 30A / 29A / 28A 6kA lcv:150A(1s) (K.G.:23.12.2024)
- UPS ESTIA HYBRID 33020 20kVA / 18kW 400V (±15%) Cosφ:0,9 max. 30A Class 1 IP20 380 / 400 / 415V (±1%) 30A / 29A / 28A 6kA lcv:150A(1s) (K.G.:23.12.2024)
- UPS ESTIA EVO HYBRID 33020 20kVA / 18kW 400V (±15%) Cosφ:0,8 max. 30A Class 1 IP20 380 / 400 / 415V (±1%) 30A / 29A / 28A 6kA lcv:150A(1s) (K.G.:23.12.2024)
- UPS ESTIA EVO HYBRID 33020 20kVA / 18kW 400V (±15%) Cosφ:0,9 max. 30A Class 1 IP20 380 / 400 / 415V (±1%) 30A / 29A / 28A 6kA lcv:150A(1s) (K.G.:23.12.2024)
- UPS ESTIA HYBRID TOWER 33010 10kVA / 9kW 400V (±15%) Cosφ:0,9 max. 15A Class 1 IP20 380 / 400 / 415V (±1%) 15A / 14A / 14A 6kA lcv:75A(1s) (K.G.:23.12.2024)
- UPS ESTIA HYBRID TOWER 33015 15kVA / 13,5kW 400V (±15%) Cosφ:0,9 max. 23A Class 1 IP20 380 / 400 / 415V (±1%) 23A / 22A / 21A 6kA lcv:115A(1s) (K.G.:23.12.2024)
- UPS ESTIA HYBRID TOWER 33020 20kVA / 18kW 400V (±15%) Cosφ:0,9 max. 30A Class 1 IP20 380 / 400 / 415V (±1%) 30A / 29A / 28A 6kA lcv:150A(1s) (K.G.:23.12.2024)
- UPS ESTIA EVO HYBRID TOWER 33010 10kVA / 9kW 400V (±15%) Cosφ:0,9 max. 15A Class 1 IP20 380 / 400 / 415V (±1%) 15A / 14A / 14A 6kA lcv:75A(1s) (K.G.:23.12.2024)
- UPS ESTIA EVO HYBRID TOWER 33015 15kVA / 13,5kW 400V (±15%) Cosφ:0,9 max. 23A Class 1 IP20 380 / 400 / 415V (±1%) 23A / 22A / 21A 6kA lcv:115A(1s) (K.G.:23.12.2024)
- UPS ESTIA EVO HYBRID TOWER 33020 20kVA / 18kW 400V (±15%) Cosφ:0,9 max. 30A Class 1 IP20 380 / 400 / 415V (±1%) 30A / 29A / 28A 6kA lcv:150A(1s) (K.G.:23.12.2024)

Akdoğan BULUT
İstanbul Belgelendirme
Müdürü V.

24/12/2025

Belgelendirme Merkezi Başkanı Adına

